ATTESTATO

ATESTACIÓN



Compliance Document

No. D 110886 0014 Rev. 00

Holder of Certificate:	Shenzhen Atess Power Technology Co.,Ltd 2nd Floor, No.23 Zhulongtian Road Shuitian Community, Shiyan Street Baoan District 518000 Shenzhen PEOPLE'S REPUBLIC OF CHINA
	FEOFLE 3 REFORLIG OF CHINA

Product:

Converter (Energy Storage Inverter)

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.:

Date,

64290243022801

BESCHEINIGUNG

ATTESTATION

2024-08-16

alj

(Billy Qiu)

 \blacklozenge

ATTESTATO

 \blacklozenge

ATESTACIÓN

 \blacklozenge

BESCHEINIGUNG



Compliance Document

No. D 110886 0014 Rev. 00

Model(s): **PCS1000**

Parameters:

Model	PCS1000	
Battery input/output parameters		
Battery type	Lithium-ion	
Maximum voltage [V _{DC}]	860	
Battery rated voltage [V _{DC}]	768	
Battery voltage range [V _{DC}]	650-860	
Maximum charge power [kW]	750	
Maximum discharge power [kW]	1040	
Maximum charge current [A _{DC}]	1154	
Maximum discharge current [A _{DC}]	1600	
Maximum charge power from grid to battery [kW]	750	
Grid terminal input parameters		
Rated input voltage [V _{AC}]	3P+PE, 400	
Rated input frequency [Hz]	50	
Maximum continuous input current from grid to battery [A _{AC}]	1082.5	
Maximum continuous input current [A _{AC}]	1082.5	
Maximum continuous input power from grid to battery [kW]	750	
Maximum continuous input active power [kW]	750	
Maximum continuous input apparent power [kVA]	750	
Grid terminal output parameters		
Rated output voltage [V _{AC}]	3P+PE, 400	
Rated output frequency [Hz]	50	
Rated output current [A _{AC}]	1443	
Maximum continuous output current [A _{AC}]	1443	
Rated output active power [kW]	1000	
Maximum output active power [kW]	1000	
Maximum output apparent power [kVA]	1000	
Power factor range	0.9 inductive(under-excited) to 0.9 capacitive(over-excited)	

Tested

Grid Connection Code for RPPs in South Africa(Version 3.1):2022

according to: